

875—95.1(89) Scope. This chapter applies to water heaters supplying potable hot water when the heat input is greater than 50,000 Btu's per hour or the water-containing capacity is greater than 50 gallons. However, if the heat input is equal to or greater than 200,000 Btu's per hour or the water-containing capacity is equal to or greater than 120 gallons, 875—Chapter 94 shall apply instead of this chapter.